

## DOCKETED

<b>Docket Number:</b>	16-BSTD-01
<b>Project Title:</b>	2013 Compliance Option for Nonresidential Lighting Alterations
<b>TN #:</b>	210757
<b>Document Title:</b>	RNM Engineering, Inc. Comments: On Option for Nonres Lighting Alterations
<b>Description:</b>	N/A
<b>Filer:</b>	System
<b>Organization:</b>	RNM Engineering, Inc.
<b>Submitter Role:</b>	Public
<b>Submission Date:</b>	3/16/2016 10:28:11 AM
<b>Docketed Date:</b>	3/14/2016

*Comment Received From: RNM Engineering, Inc.*

*Submitted On: 3/16/2016*

*Docket Number: 16-BSTD-01*

## **On Option for Nonres Lighting Alterations**

*Additional submitted attachment is included below.*

March 14, 2016

California Energy Commission  
Dockets Unit  
1516 Ninth Street, MS 4  
Sacramento, CA 95814-5512

**Re: Docket # 16-BSTD-01 Option for Nonres Lighting Alterations**

I respectfully submit the following comments for revisions to the California Building Energy Efficiency Standards, California Code of Regulations, Title 24, Part 6.

**Section 141.0(b)2I - I. Entire Luminaire Alterations**

Acceptance testing requirements of Section 130.4 are not required for alterations where lighting controls are added to control 20 or fewer luminaires

**Section 141.0(b)2J - J. Luminaire Component Modifications**

Acceptance testing requirements of Section 130.4 are not required for modifications where lighting controls are added to control 20 or fewer luminaires

Please make available the justification for not requiring acceptance testing of controls for 20 or fewer luminaires.

Thank you for your consideration of these comments.

Respectfully submitted,



Richard N. Miller, PE, LEED AP, IES, IAEI, IEEE, LC  
President, RNM Engineering, Inc.