Russell City - Summary

14.7 ac 1.68 ac wetlands.

600 MW natural gas fired generator

145' high ~~[illegible]~~

NO_x 2 - 5 ppmvd

- Advanced wastewater Treatment (AWT) → from EBDA + USD
  - use 2° treated water
  - 3.33 - 5.27 mgd ↳ Peak · Fresh water
  - water temp 60-90°F

→ Connect power @ Eastshore substation

EPA INITIATION Received March 13, 2002

Power lines should have bird deverters

What about additive chemicals in effluent?
0.5 mg/l Cu ?

No discussion of How project may facilitate development in area, or what is baseline + projected.

~~[illegible]~~ 2000 ALA air NO_x 113.57 t/d
Bay Area → 558.15 t/d
RCEC → 134.6 t/d ⇒ 0.37 t/d ⇒ 815.71 lb/day
↳ represents 0.325% ALA
0.066% BA

Stuart Hoga
654-3882 FAX
654-4161 #

David ~~Kumpler~~ Wampler, EPA
(March 11, 2002 initiated new lead.
(415) 972-3975
Air Division