



DOCKET	
79-AFC-4C	
DATE	DEC 07 2006
RECD.	DEC 08 2006

770 L Street, Suite 800
Sacramento, California 95814
main 916.447.0700
fax 916.447.4781
www.stoel.com

December 7, 2006

JOHN A. MCKINSEY
Direct (916) 319-4746
jamckinsey@stoel.com

VIA E-MAIL AND HAND DELIVERY

Christopher Meyer
Compliance Project Manager
California Energy Commission
1516 9th Street
Sacramento, CA 95814

Re: Bottle Rock Power Plant

Dear Mr. Meyer:

On behalf of Bottle Rock Power Corporation ("BRPC"), the following comments are made regarding the California Energy Commission's ("CEC") Staff Analysis of BRPC's Petition to Change the Ownership, Allow the Restart of Operation After Suspension, and Allow 11 Facility Design Changes ("Petition"). First, however, BRPC wishes to thank the Staff for its detailed analysis of the Petition and for promoting the value of this important geothermal project.

There is a minor change BRPC requests be made to one Condition of Certification. BRPC requests that the phrase "and/or hydrogen peroxide" be inserted immediately after the words "iron chelate" in the second sentence of Condition 1-3 (Air Quality). This minor modification will ensure that Condition 1-3 is consistent with those other conditions allowing the use of hydrogen peroxide for emissions control. BRPC intends to use iron chelate in lieu of hydrogen peroxide. Upon establishing the feasibility of ceasing use of hydrogen peroxide, BRPC plans to submit a request to both the CEC and the LCAQMD for approval to eliminate hydrogen peroxide use at the Bottle Rock Power Plant.

With this change, BRPC accepts all other Conditions of Certification and looks forward to the Commission's approval of its Petition next week.

Very truly yours,

John A. McKinsey

cc: Ron Sues
Tom King
Lee Bailey

Oregon
Washington
California
Utah
Idaho