

# Diablo Canyon Fire Department

## 2007 Fire Responses

Date	Incident #	Type of Fire Response
1/14/07	07-002	Wildland Fire (Fields Ranch) Approx 300 acres
2/23/07	07-004	Butt-can Fire (Unit 2 Tx Yard) (see attached A/R)
3/23/07	07-008	Smell of Smoke (Maint Shop Bldg) (see A/R & Eval)
5/13/07	07-023	Structure Fire (Stairwell - East side of Warehouse A)
6/10/07	None assigned	Fire Alarm Admin Building (see attached A/R only)
6/12/07	07-032	Butt-can Fire (Outside Trailer 260)
7/5/07	07-033	Butt-can Fire (Outside Building 201)
9/10/07	07-039	Electrical / Smoke odor (Trailer 171)

# Incident Response Log - 2007

Response Number	Response Code(s) *	Date	Description of Response	Log Entry By:	A/R Number
07-001	M	1-4-07	51 Female w/ chest Pains	MP	
07-002	F	1-15-07	Structure fire / wildland fire north of plant	EC	
07-003	H	1-25-07	Possible carbon release by the tank	EC	
07-004	F	2-23-07	SMOKING CIGARETTE BUTT RECEPTACLE	EC	A06891500
07-005	H	2-26-07	Acid leak U2 Butress inside berm	DTS	A06891683
07-006	M	3-14-07	Medical Aide (Knee pain)	EC	N/A
07-007	F	3-17-07	Smoke Detector Activation Admin Building	DTS	A06891224
07-008	F	3-23-07	Fire in Electrical Panel Roof Maintenance Training Bldg	DTS	A06891615
07-009	M	3-24-07	med Ad (cpt feeling vert e Fitness Trainer)	EC	N/A
07-010	M	3-24-07	med Ad (Diabetic Emergency pit to Agave) <sup>UWS</sup>		
07-011	M	4-4-07	Small Abrasion on Rt. Thumb	DTS	
07-012	M	4-16-07	MED AID (Dizzy officer AT W.C. office)	EC	
07-013	M	4-25-07	med Ad (Bee sting) (Sim Bldg)	EC	N/A
07-014	M	4-26-07	med Ad (minor head injury) (Turner nights)	EC	N/A
07-015	M	4-30-07	Fall in containment RT	MAT	
07-016	M	5-1-07	Heart related emerg. MINOR	MAT	
07-017	M	5-6-07	* Sprained ankle @ med facility	EC	N/A
07-018	M	5-9-07	FALL WITH FACIAL CUT NW CONDENSED AIR CONTAINMENT <sup>FENCE</sup>		
07-019	M	5-11-07	Lacerated Finger	ILW	
07-020	M	5-11-07	TWISTED KNEE	EC	N/A
				MP	N/A

# Incident Response Log - 2007

Response Number	Response Code(s) *	Date	Description of Response	Log Entry By:	A/R Number
07-021	M	5-11-07	WELDING BURN	AD	N/A
07-022	R	5-12-07	ELEVATOR IN ADMIN AND TURBINE	DL	N/A
07-023	F	5-12-07	EAST OF WHISE A. ON HANDRAIL OF STAIRWELL	DL	N/A
07-024	M	5-12-07	POSSIBLE HEART ATTACK	DL	N/A
07-025	M	5-12-07	FALL w/ LOWER BACK INJURY	DL	N/A
07-026	M	5-17-07	LIGHT HEADNESS (SECURITY BLDG)	AD	N/A
07-027	M	5-20-07	CHEST PAIN	DL	N/A
07-028	M	5-21	LOWER BACK PAIN	DL	N/A
07-029	M	5-22	CHEST PAIN	DL	N/A
07-030	F	6-5	ADMIN ALARM BURNED TOUGH	DL	N/A
07-031	F	6-10	ADMIN ALARM	DL	107100148
07-032	F	6-12-07	Smoldering butt can Tr1 260 (Fire Alarm Soundeds)	EC	
07-033	F	7-5-07	Smoldering butt can Bld 201	EC	
07-034	M	7-20-07	LACERATION RT. LEG	CSBP	N/A
07-035	M	7-19-07	(Late Entry) med Ad Severe Back Pain Intake	EC	N/A
07-036	M	8-4-07	EYE IRRITATION	RW	N/A
07-037	F	8-21-07	911 - Admin 4th Floor Sink DET. KIVANOW pipin	DL	N/A
07-038	H	8-30-07	100 gallon Diesel Spill inside secondary containment at diesel tank east of Admin	DL	DTS
07-039	F	9-10-07	Elec Smoke (Bld 17U) 3 wide across from vis	EC	N/A
07-040	M	9-14-07	LACERATION RIGHT THUMB	DL	N/A

# Incident Response Log - 2007

Response Number	Response Code(s) *	Date	Description of Response	Log Entry By:	A/R Number
07-041	M	9/21/07	CRUSHING INJURY TO INDEX FINGER GRANITE @ BUILDING	[Signature]	
07-042	F	9/22/07	FLA ADMIN BLDG 4TH FLOOR DETECTOR	[Signature]	
07-043	F	9/24/07	Smoking Butt CAN <sup>2</sup> PFD TRAILER MGA	AGWJL	
07-044	M	9-25-07	FALL FROM WALL 20' LOWER LEFT BACK	JR	
07-045	H	9-25-07	BUMC Warehouse (ACC)		
07-046	M	9-28-07	Fall, Ankle	Tune	
07-047	M	10/3/07	Bicep pain	Rigby	
07-048	M	10/3/07	Chest pain / SOB	Rigby	
07-049	M/R	10/25/07	ROLL OVER ON ACCESS ROAD DRIVER & PASSENGER MEDICAL RESOURCES	Fehl	
07-050	H	10-26-07	PWR. STEERING FWD RELEASE, 230KV YARD	JBL	
07-051	H	11-7-07	DIESEL FUEL RELEASE, AVILA GATIE	JBL	
07-052	M	11/16/07	Lt Pinky laceration	DTS	
07-053	M	11/27/07	Med Aid (SGT Traker) Hypertension / Blurred vision (Escorted to medical)	EC	n/a
07-054	F	11/27/07	Small bearings / Butt Can (Arco 10 Circus Test)	EC	n/a
07-055	M	12/14/07	MED AID - Pt LIGHT HEADS AND DIZZY	RWJ	N/A
07-056	M	12/20/07	Knee pain	EC for mp	N/A
07-057	F	12/20/07	Poss Arcing A/c unit	EC	n/a
07-058	F	12/20/07	False Alarm (Admin Bldg Drywall dust in detector)	EC	n/a
07-059	M	12/20/07	Med Aid (Abod Pain) Tx to Dr by Priv vehicle	EC	n/a
07-060	R	12/23/07	Rescue Trapped Security Guard from Guard Shack	BTS	

# DIABLO CANYON POWER PLANT

## FIRE INCIDENT REPORT

## INDUSTRIAL FIRE OFFICER

INCIDENT LOCATION : Fields Ranch (Incident Name "Diablo")

INCIDENT # : 07-002

DATE : 1/14/07

DISPATCHED : 1515 ON SCENE: 1530

EXTINGUISHED : 1-17@ 1700

AVAILABLE : 1900 (1/14)

### TYPE OF INCIDENT

STRUCTURE FIRE

WILDLAND FIRE

VEHICLE FIRE

OTHER  Specify:

### INCIDENT DATA

FIRE AREA :

n/a

FIRE ZONE :

n/a

OCCUPANCY :

residential and wildland

FIRE ORIGIN LOCATION :

double wide trailer above Fields Ranch

BUILDING CONSTRUCTION :

wood and metal

EXTENT WHEN DISCOVERED :

trailer completely burned to foundation with approx 10 acre wildland fire

EXTENT WHEN EXTINGUISHED :

trailer completely destroyed

CAUSE OF FIRE :

unknown at this time (investigation in progress)

WHAT BURNED :

double wide trailer and approx 350 acres of wildland

ESTIMATED PROPERTY LOSS :

None for Diabo Canyon Power Plant (trailer owned by leasee)

DAMAGE TO :

Trailer and wildland

COMMAND POST LOCATION :

Fields Ranch

STAGING AREA :

Crowbar Canyon Road @ Main Diablo dirt road North of Plant

LIST AGENCIES NOTIFIED :

Ops, Security, CDF, SLO County Sheriff, PGE Biologist, PGE Govt. Relations,

### RESPONDERS AT SCENE

FIRE OFFICERS:

Frazier, Carter, Turner, Wimberly, Rigby (initial). Called in throughout the next three days: Beile, Ward, Felix, Porte, & Schwarz. Others included on duty crew members over the four days

SAFETY PERSONNEL:

CDF Safety Officer Paul VanGerwin

MEDICAL PERSONNEL:

Craig Gallagher called in to staff the Med Facility on dayshift Monday 1/15

BRIGADE MEMBERS:

none

OPERATIONS:

none

SECURITY:

numerous Officers with a Watch Commander at the Incident Command Post

OFFSITE FIRE:

Numerous CDF Engines, AGFD, Atascadero City, SB County, Ventura County, etc...

OFFSITE AMBULANCE:

none

OTHER (SPECIFY):

Jim Becker, Bob Waltos, Mike Meko, PGE Govt Relations, Sally Krenn,

**ICS POSITIONS**

INCIDENT COMMANDER : CDF Phil Veneris, Mike Abarca, and Chris Paris  
SAFETY OFFICER : CDF Paul VanGerwin  
SECURITY LIAISON : PGE Watch Commander  
OPERATIONS CHIEF : Staffed by CDF  
LOGISTICS CHIEF : CDF Mike Medico  
PLANNING CHIEF : CDF Rob Lewin  
STAGING OFFICER : Staffed by CDF  
MEDICAL LEADER : none  
OTHER (Specify) :

**INCIDENT REPORTING**

REPORTING PARTY : Tenant of double wide trailer

CONTROL ROOM NOTIFIED

No  Yes  VIA: Phone  779  Other  Specify: from Security

INDUSTRIAL FIRE OFFICER NOTIFIED :

No  Yes  VIA: Phone  Pager  PA  Other  Specify: from Security

WITNESS(ES)

Name and Title : Tenant of double wide (unknown name)

**LIST FIRE PROTECTION OR DETECTION SYSTEM(S) ACTIVATED**

None

**LIST FIRE FIGHTING EQUIPMENT USED**

Diablo E9799 & P9769

**NARRATIVE**

Received a phone call from Security at approx 1515 hours on Sunday 1/14/07 of heavy smoke north of the plant - possible wildland fire and possible Fields Ranch structure fire. P9769 and E9799 responded. Upon arrival, found double wide trailer behind the Fields Ranch fully involved and burnt to the ground with an approx 10 acre wildland fire heading up the canyon behind the Fields Ranch. CDF requested. E9799 (Carter, Wimberly, & Rigby) took the "north flank" by the double wide trailer with approx 200' of hose and took the Fields Ranch house for structure protection. P9769 (Frazier & Turner) headed up CrowBar Canyon Road to scout out the fire potential for our 230V lines. CDF B3411 arrived on scene and assumed command. CDF E62 attached more lines to our Engine for additional firefighting and structure protection. Once our tank was empty, B3411 had our engine swap with E262 so we could return to Diablo for power plant coverage. E9799 returned to quarters at approx 1900 hrs. Two additional personnel called in to maintain our staffing at five. P9769 took Div E Group Sup (east side) and worked all night on the eastern flank with two CDF Type 3's, a dozer, and a water tender. The southern edge of the fire has stayed about 1 mile away from our 230V lines. Numerous other mutual aid responders arrived throughout the first couple hours, staffing Div A (north side), Div Z (south side).

Day two (1/15/07). P9769 returned to the station for fuel, supplies, and a fresh crew at approx 0800. A fresh crew of three (Beile, Wimberly, and Rigby) responded back to fire area and were assigned to Div Z and assisted with dozer line clean up and backfiring. Three helicopters and one fixed wing arrived. Total personnel on the morning of day two was approx 220 people. Fire size was estimated at 500-600.

P9769 was released at approx 1800 hrs. Night Ops coverage for this night consisted of two CDF Strike Teams, two dozers, and two water tenders.

Day three (11/16/07), P9769 was staffed with three (Beile, Penner, & Schwarz) and are were sent to staging at CrowBar Canyon Road. P9769 worked smokers and hot spots. CDF fire officials state fire is 70% contained and is burning towards Montana De Oro (230V lines threat risk is low).

Day four (1/17/07), P9769 was staffed with Schroeder, Coito, and Depew...working smokers and hot spots. CDF officials state fire is 100% contained and extinguished at 1700.

Day five (1/18/07). Fire area patrolled - no suppression needed.

Day six (1/19/007). Fire area patrolled - no suppression needed.

Day seven (1/20/07). Fire area patrolled. One flare up was found inside the control lines. Two CDF Engines responded for extinguishment. One CDF Engine will return tomorrow to pick up hose lines and to patrol fire.

Day eight (1/21/07). Fire area patrolled - one small hot spot located and was extinguished by hand tools.

Day nine (1/22/07). Fire area patrolled twice - no suppression needed.

Day ten (1/23/07). Fire area patrolled. Two small hotspots located - extinguished with water and hand tools.

Day eleven (1/24/07) Fire area patrolled by DCFD - no suppression need. Fire area was also patrolled by CDF - no suppression needed.

Day twelve (1/25/07) Incident terminated (and light rain fell through-out the day)

On 1/26/07 and 1/27/07, DCFD patrolled area. No smokers or hot spots located.

---

NAME : Eric J. Carter                      DATE : 1/16/07                      SIGNATURE: \_\_\_\_\_

REVIEWED BY : \_\_\_\_\_                      DATE : \_\_\_\_\_

# DIABLO CANYON POWER PLANT

## FIRE INCIDENT REPORT

## INDUSTRIAL FIRE OFFICER

INCIDENT LOCATION : Unit 2 Transformer Yard at Pipe Rack

INCIDENT # : 07-004

DATE : 02/23/07

DISPATCHED : 0002

ON SCENE: 0015

EXTINGUISHED : 0025

AVAILABLE : 0034

### TYPE OF INCIDENT

STRUCTURE FIRE

WILDLAND FIRE

VEHICLE FIRE

OTHER  Specify: Smoldering Smoking Materials in Receptacle

### INCIDENT DATA

FIRE AREA : n/a  
FIRE ZONE : n/a  
OCCUPANCY : Industrial  
FIRE ORIGIN LOCATION : Cigarette butt disposal receptacle  
BUILDING CONSTRUCTION : N/A  
EXTENT WHEN DISCOVERED : Small amount of smoke from receptacle  
EXTENT WHEN EXTINGUISHED : Contents extinguished, no damage to container/receptacle  
CAUSE OF FIRE : Incomplete extinguishment of smoking materials  
WHAT BURNED : Discarded smoking materials  
ESTIMATED PROPERTY LOSS : None  
DAMAGE TO : N/A  
COMMAND POST LOCATION : U2 Transformer Yard @ Pipe Rack  
STAGING AREA : Parking Lot south of Security Building  
LIST AGENCIES NOTIFIED : Ops, Security

### RESPONDERS AT SCENE

FIRE OFFICERS: FC Ellis, FF Ward, FF Penner  
SAFETY PERSONNEL: None  
MEDICAL PERSONNEL: None  
BRIGADE MEMBERS: None  
OPERATIONS: Ops Responder Bob Wathen  
SECURITY: (1) officer as escort: responders were searched @ scene, officer was released.  
OFFSITE FIRE: None  
OFFSITE AMBULANCE: None  
OTHER (SPECIFY): Nuclear Operator Eric Lowe

### ICS POSITIONS

INCIDENT COMMANDER : FC Ellis  
SAFETY OFFICER : FC Ellis  
SECURITY LIAISON : Not established  
OPERATIONS CHIEF : Not established  
LOGISTICS CHIEF : Not established

PLANNING CHIEF : Not established  
STAGING OFFICER : Not established  
MEDICAL LEADER : Not established  
OTHER (Specify) :

**INCIDENT REPORTING**

REPORTING PARTY : Unknown

CONTROL ROOM NOTIFIED

No  Yes  VIA: Phone  779  Other  Specify:

INDUSTRIAL FIRE OFFICER NOTIFIED :

No  Yes  VIA: Phone  Pager  PA  Other  Specify: Fire Alarm

WITNESS(ES)

Name and Title :

**LIST FIRE PROTECTION OR DETECTION SYSTEM(S) ACTIVATED**

None

**LIST FIRE FIGHTING EQUIPMENT USED**

Diablo E9799 & P9769

**NARRATIVE**

A smoldering cigarette butt receptacle was found and reported to the control room. Unknown how the decision was made to sound the fire alarm. Difficulties experienced during the notification process (779/bridge line did not function properly) are documented in A/R A0689501. Refer to A/R A0689500 for further details on the fire response.

---

NAME : J. Scott Ellis                      DATE : 02/23/07      SIGNATURE: \_\_\_\_\_

REVIEWED BY : \_\_\_\_\_                      DATE : \_\_\_\_\_

# DIABLO CANYON POWER PLANT

## FIRE INCIDENT REPORT

## INDUSTRIAL FIRE OFFICER

INCIDENT LOCATION : Maintenance Shop Building

INCIDENT # : 07-008

DATE : 3-23-07

DISPATCHED : 0300

ON SCENE: 0304

EXTINGUISHED : 0317

AVAILABLE :

### TYPE OF INCIDENT

STRUCTURE FIRE

WILDLAND FIRE

VEHICLE FIRE

OTHER  Specify:

### INCIDENT DATA

FIRE AREA : Electrical panel for ventilation equipment

FIRE ZONE : Roof of Maintenance Shop Building

OCCUPANCY : Office Building

FIRE ORIGIN LOCATION : Inside electrical panel

BUILDING CONSTRUCTION :

EXTENT WHEN DISCOVERED :

EXTENT WHEN EXTINGUISHED :

CAUSE OF FIRE : Failure inside electrical panel

WHAT BURNED : Electrical panel components and paper

ESTIMATED PROPERTY LOSS : \$2000

DAMAGE TO : Electrical panel

COMMAND POST LOCATION : parkinglot adjacent to building

STAGING AREA : none

LIST AGENCIES NOTIFIED : none

### RESPONDERS AT SCENE

FIRE OFFICERS: Stocks, Frazier, Porte, Rigby, Wimberly

SAFETY PERSONNEL: none

MEDICAL PERSONNEL: none

BRIGADE MEMBERS: none

OPERATIONS: Warren Brown

SECURITY: Yes

OFFSITE FIRE: none

OFFSITE AMBULANCE: none

OTHER (SPECIFY): Building Services

### ICS POSITIONS

INCIDENT COMMANDER : Stocks

SAFETY OFFICER :

SECURITY LIAISON :

OPERATIONS CHIEF :

LOGISTICS CHIEF :

PLANNING CHIEF :

STAGING OFFICER :  
MEDICAL LEADER :  
OTHER (Specify) :

### INCIDENT REPORTING

REPORTING PARTY :

CONTROL ROOM NOTIFIED

No  Yes  VIA: Phone  779  Other  Specify:

INDUSTRIAL FIRE OFFICER NOTIFIED :

No  Yes  VIA: Phone  Pager  PA  Other  Specify: Alarm sounded

WITNESS(ES)

Name and Title :

### LIST FIRE PROTECTION OR DETECTION SYSTEM(S) ACTIVATED

None

### LIST FIRE FIGHTING EQUIPMENT USED

None

### NARRATIVE

See AR A0691615. The alarm was sounded for smell of smoke on the second floor of the maintenance shop building. As we were driving to the building there was no visible signs of smoke or fire. Upon arrival there were security guards on the second floor of the building. We had two teams of two search the building for the source of the smell. One team was using the TIC. Upon searching the roof ventilation area smoke was seen. There was smoke coming from an electrical panel. The panel cover was unable to be removed. There was an adjacent panel that the cover could be opened. Upon opening the panel door smoldering ashes were on the bottom of the panel. Stirring the ashes caused them to ignite. They went out as soon as they ignited. Apparently a fuse or something failed in the panel causing something hot to fall to the bottom of the panel. There were some papers or a book in the bottom of the panel that ignited. We were unable to determine how to isolate the power to the panel. There was a breaker next to the panel it was not labeled so that we could understand what the breaker isolated. The Ops Responder did open that breaker and several other push button breakers in the panel. We then down stairs to the main electrical panel on the first floor. In the electrical room there was a 600 amp breaker tripped. Again the labeling of breaker made us unsure as to what it isolated. An AR EVAL (A0691614) was written to determine if it is appropriate to keep papers inside of electrical panels. Also to determine if better labeling of the panels and circuit breakers is necessary. The control room had difficulty getting in touch with anyone from Building Services or A&J Refrigeration. Since we were unsure if the power to the panel had been isolated two fire fighters remained on scene at the panel until a representative arrived from Building Services. The engine was also left at the building. The building was walked down with the Sirius to determine if it was safe for occupants. The air smelled but the air quality was fine.

A0691615

NAME : Dan Stocks                      DATE : 3-23-07                      SIGNATURE: \_\_\_\_\_

REVIEWED BY : \_\_\_\_\_                      DATE : \_\_\_\_\_

# DIABLO CANYON POWER PLANT

## FIRE INCIDENT REPORT

## INDUSTRIAL FIRE OFFICER

INCIDENT LOCATION : East side of Warehouse A in the wooden stairwell

INCIDENT # : 07-023

DATE : 05-13-07

DISPATCHED : 1635

ON SCENE: 1637

EXTINGUISHED : 1633

AVAILABLE : 1700

### TYPE OF INCIDENT

STRUCTURE FIRE

WILDLAND FIRE

VEHICLE FIRE

OTHER  Specify:

### INCIDENT DATA

FIRE AREA : Unit 1 East of Warehouse A  
FIRE ZONE : Above Unit 1 Transformer area. Behind Whse. A outside  
OCCUPANCY : N/A  
FIRE ORIGIN LOCATION : 4x4 wooden post support for stair handrail  
BUILDING CONSTRUCTION : wood  
EXTENT WHEN DISCOVERED : small flame confined to wooden post  
EXTENT WHEN EXTINGUISHED : 4x4 wooden post  
CAUSE OF FIRE : unknown  
WHAT BURNED : 4x4 post and 2x4 wooden support  
ESTIMATED PROPERTY LOSS : zero as stairs was in process of being replaced  
DAMAGE TO : stairwell and sidewalk  
COMMAND POST LOCATION : N/A  
STAGING AREA : N/A  
LIST AGENCIES NOTIFIED : N/A fire reported out during 779 call

### RESPONDERS AT SCENE

FIRE OFFICERS: Chief Paris, Captain Stocks, Captain Beile  
SAFETY PERSONNEL: None  
MEDICAL PERSONNEL: N/A  
BRIGADE MEMBERS: N/A  
OPERATIONS: N/A  
SECURITY: 3 total. 2 in Brush 9769 as escorts and one footpatrol  
OFFSITE FIRE: N/A fire reported out  
OFFSITE AMBULANCE: N/A  
OTHER (SPECIFY): Ray Richardson / pgr 4841 Renelle Hayes reporting party

### ICS POSITIONS

INCIDENT COMMANDER : Chief Paris  
SAFETY OFFICER : N/A  
SECURITY LIAISON : N/A  
OPERATIONS CHIEF : N/A  
LOGISTICS CHIEF : N/A  
PLANNING CHIEF : N/A

STAGING OFFICER : N/A  
MEDICAL LEADER : N/A  
OTHER (Specify) : Captain Beile and Stocks on scene

### **INCIDENT REPORTING**

REPORTING PARTY :

CONTROL ROOM NOTIFIED

No  Yes  VIA: Phone  779  Other  Specify:

INDUSTRIAL FIRE OFFICER NOTIFIED :

No  Yes  VIA: Phone  Pager  PA  Other  Specify:

WITNESS(ES)

Name and Title : Ray Richardson

### **LIST FIRE PROTECTION OR DETECTION SYSTEM(S) ACTIVATED**

One dry chemical extinguisher and a 5 gallon bottle of water used by Ray Richardson upon discovery and extinguished fire.

### **LIST FIRE FIGHTING EQUIPMENT USED**

None. Fire out upon arrival

### **NARRATIVE**

A small fire at the base of the stairs located on the eastside of Warehouse A was reported out by but smoldering via 779 by Renelle Hays who was in the trailer # 520 at the time. Ray Richardson utilized a dry chemical extinguisher and a 5 gallon bottle of water to extinguish the flame. As Ray extinguished the fire a female coworker dialed 779 and reported the fire location and stated the fire was out but still smoldering. Fire Captain Dan Stocks responded on foot and was first on scene. Chief Paris also responded on foot and arrived second. Captain Beile responded via Brush 9769 from Station 97 followed by Engine 9799 which staged outside the protected area. The 4x4 post was physically removed from the stairs and Ray Richardson posted as firewatch for 30 minutes. An investigation as to cause of the fire was conducted and the cause was not determined. Action Request A0696461 was initiated and the fire scene documented with photographs. Written statements were taken from persons who were in trailer 520 at the time of the fire was reported.

---

---

NAME : \_\_\_\_\_ DATE : \_\_\_\_\_ SIGNATURE: \_\_\_\_\_

REVIEWED BY : \_\_\_\_\_ DATE : \_\_\_\_\_

# DIABLO CANYON POWER PLANT

## FIRE INCIDENT REPORT

## INDUSTRIAL FIRE OFFICER

INCIDENT LOCATION : TRL 260

INCIDENT # : 07-032

DATE : 06-12-07

DISPATCHED : 1730

ON SCENE: 1730

EXTINGUISHED : 1730

AVAILABLE : 1730

### TYPE OF INCIDENT

STRUCTURE FIRE

WILDLAND FIRE

VEHICLE FIRE

OTHER  Specify: Smoldering

### INCIDENT DATA

FIRE AREA :

FIRE ZONE :

OCCUPANCY :

FIRE ORIGIN LOCATION :

Butt Can

BUILDING CONSTRUCTION :

EXTENT WHEN DISCOVERED :

Smoldering

EXTENT WHEN EXTINGUISHED :

Extinguished

CAUSE OF FIRE :

Cigarette butt

WHAT BURNED :

Butts

ESTIMATED PROPERTY LOSS :

none

DAMAGE TO :

none

COMMAND POST LOCATION :

STAGING AREA :

LIST AGENCIES NOTIFIED :

### RESPONDERS AT SCENE

FIRE OFFICERS: Carter, Porte, Cappelluti, Coito

SAFETY PERSONNEL:

MEDICAL PERSONNEL:

BRIGADE MEMBERS:

OPERATIONS:

SECURITY:

OFFSITE FIRE:

OFFSITE AMBULANCE:

OTHER (SPECIFY):

### ICS POSITIONS

INCIDENT COMMANDER :

SAFETY OFFICER :

SECURITY LIAISON :

OPERATIONS CHIEF :

LOGISTICS CHIEF :

PLANNING CHIEF :

STAGING OFFICER :  
MEDICAL LEADER :  
OTHER (Specify) :

**INCIDENT REPORTING**

REPORTING PARTY : Unknown

CONTROL ROOM NOTIFIED

No  Yes  VIA: Phone  779  Other  Specify:

INDUSTRIAL FIRE OFFICER NOTIFIED :

No  Yes  VIA: Phone  Pager  PA  Other  Specify:

WITNESS(ES)

Name and Title :

**LIST FIRE PROTECTION OR DETECTION SYSTEM(S) ACTIVATED**

none

**LIST FIRE FIGHTING EQUIPMENT USED**

5 gallon bottle of water

**NARRATIVE**

Responded to a smoldering butt can at Trl 260. Upon arrival, opened lid and placed approx 1 gallon of water on numerous cigarette butts. Smoldering butts were extinguished

---

---

NAME :

DATE :

SIGNATURE: \_\_\_\_\_

REVIEWED BY : \_\_\_\_\_

DATE : \_\_\_\_\_

# DIABLO CANYON POWER PLANT

## FIRE INCIDENT REPORT

## INDUSTRIAL FIRE OFFICER

INCIDENT LOCATION : Outside NE Corner of Building 201  
INCIDENT # : 07-033  
DATE : 07-05-05  
DISPATCHED : 1430 ON SCENE: 1431 EXTINGUISHED : 1432  
AVAILABLE : 1432

### TYPE OF INCIDENT

STRUCTURE FIRE  WILDLAND FIRE  VEHICLE FIRE   
OTHER  Specify: Smoldering butt can

### INCIDENT DATA

FIRE AREA : n/a  
FIRE ZONE : n/a  
OCCUPANCY : n/a  
FIRE ORIGIN LOCATION : n/a  
BUILDING CONSTRUCTION : n/a  
EXTENT WHEN DISCOVERED : smoldering  
EXTENT WHEN EXTINGUISHED : extinguished  
CAUSE OF FIRE : cigarette  
WHAT BURNED : cigarette butts  
ESTIMATED PROPERTY LOSS : none  
DAMAGE TO : n/a  
COMMAND POST LOCATION : not established  
STAGING AREA : n/a  
LIST AGENCIES NOTIFIED : n/a

### RESPONDERS AT SCENE

FIRE OFFICERS: Cappelluti, Felix  
SAFETY PERSONNEL: n/a  
MEDICAL PERSONNEL: n/a  
BRIGADE MEMBERS: n/a  
OPERATIONS: n/a  
SECURITY: n/a  
OFFSITE FIRE: n/a  
OFFSITE AMBULANCE: n/a  
OTHER (SPECIFY): n/a

### ICS POSITIONS

INCIDENT COMMANDER : not established  
SAFETY OFFICER : n/a  
SECURITY LIAISON : n/a  
OPERATIONS CHIEF : n/a  
LOGISTICS CHIEF : n/a  
PLANNING CHIEF : n/a

STAGING OFFICER : n/a  
MEDICAL LEADER : n/a  
OTHER (Specify) : n/a

**INCIDENT REPORTING**

REPORTING PARTY : Building 201 occupant

CONTROL ROOM NOTIFIED

No  Yes  VIA: Phone  779  Other  Specify:

INDUSTRIAL FIRE OFFICER NOTIFIED :

No  Yes  VIA: Phone  Pager  PA  Other  Specify:

WITNESS(ES)

Name and Title : unknown

**LIST FIRE PROTECTION OR DETECTION SYSTEM(S) ACTIVATED**

none

**LIST FIRE FIGHTING EQUIPMENT USED**

1 gallon of water from a 5 gallon water bottle

**NARRATIVE**

Received a phone call from the Unit 1 SFM to investigate a smoldering butt can outside the NE corner of Building 201. Upon arrival, found a small butt can smoldering. Removed lid, and poured approx 1 gallon of water on numerous smoldering cigarette butts and stirred to wet down all contents. Ensured smoldering butts were extinguished and replaced lid. Cleared scene.

---

---

NAME : Eric Carter                      DATE : 7/5/07                      SIGNATURE: \_\_\_\_\_

REVIEWED BY : \_\_\_\_\_                      DATE : \_\_\_\_\_

# DIABLO CANYON POWER PLANT

## FIRE INCIDENT REPORT

## INDUSTRIAL FIRE OFFICER

INCIDENT LOCATION : Trl 171 (3-Wide across from VIS)

INCIDENT # : 07-039

DATE : 9-10-07

DISPATCHED : 1200 ON SCENE: 1203 EXTINGUISHED : N/A

AVAILABLE : 1203

### TYPE OF INCIDENT

STRUCTURE FIRE

WILDLAND FIRE

VEHICLE FIRE

OTHER  Specify: Electrical Odor

### INCIDENT DATA

FIRE AREA : N/A  
FIRE ZONE : N/A  
OCCUPANCY : Office  
FIRE ORIGIN LOCATION : N/A  
BUILDING CONSTRUCTION : Mobile Office  
EXTENT WHEN DISCOVERED : Electrical ballast odor  
EXTENT WHEN EXTINGUISHED : N/A  
CAUSE OF FIRE : N/A  
WHAT BURNED : N/A  
ESTIMATED PROPERTY LOSS : ballast on flourescent light  
DAMAGE TO : N/A  
COMMAND POST LOCATION : N/A  
STAGING AREA : N/A  
LIST AGENCIES NOTIFIED : N/A

### RESPONDERS AT SCENE

FIRE OFFICERS: Carter, Beile, Cappelluti, Porte, Felix, & Coito  
SAFETY PERSONNEL: N/A  
MEDICAL PERSONNEL: N/A  
BRIGADE MEMBERS: N/A  
OPERATIONS: Requested by fire to not respond on bridge line  
SECURITY: numerous  
OFFSITE FIRE: not requested  
OFFSITE AMBULANCE: N/A  
OTHER (SPECIFY): N/A

### ICS POSITIONS

INCIDENT COMMANDER : Carter  
SAFETY OFFICER : Beile  
SECURITY LIAISON : N/A  
OPERATIONS CHIEF : N/A  
LOGISTICS CHIEF : N/A  
PLANNING CHIEF : N/A

STAGING OFFICER : N/A  
MEDICAL LEADER : N/A  
OTHER (Specify) : N/A

**INCIDENT REPORTING**

REPORTING PARTY : Bill Ryan

CONTROL ROOM NOTIFIED

No  Yes  VIA: Phone  779  Other  Specify:

INDUSTRIAL FIRE OFFICER NOTIFIED :

No  Yes  VIA: Phone  Pager  PA  Other  Specify: Fire Alarm

WITNESS(ES)

Name and Title : N/A

**LIST FIRE PROTECTION OR DETECTION SYSTEM(S) ACTIVATED**

None

**LIST FIRE FIGHTING EQUIPMENT USED**

Thermal Imaging Camera & Attic Ladder

**NARRATIVE**

Responded to an electrical odor in Trl 171. Control Room reported that both occupants were outside the building and nobody was inside. Upon arrival, found nothing showing and investigating. Upon making entry, Capt Beile reports a ballast type odor. Using the TIC and our attic ladder (and isolating the heaviest odor to the right rear office), one ballast was located with an elevated temperature. This flourescent light fixture was also flickering on and off. The bulbs were removed from this fixture and the light switch secured with a caution sign. Unit 1 SFM updated via phone. Building Services notified for repair. Window left open in rear office for odor removal. Fire cleared scene

---

---

NAME : Eric Carter

DATE : 9-10-07

SIGNATURE: \_\_\_\_\_

REVIEWED BY : \_\_\_\_\_

DATE : \_\_\_\_\_

# DIABLO CANYON POWER PLANT

## FIRE INCIDENT REPORT

## INDUSTRIAL FIRE OFFICER

INCIDENT LOCATION : Area 10 (by Circus Tent)

INCIDENT # : 07-054

DATE : 11-27-07

DISPATCHED : 0845

ON SCENE: 0847

EXTINGUISHED : 0847

AVAILABLE : 0847

### TYPE OF INCIDENT

STRUCTURE FIRE

WILDLAND FIRE

VEHICLE FIRE

OTHER  Specify: Smoldering butt can

### INCIDENT DATA

FIRE AREA :

n/a

FIRE ZONE :

n/a

OCCUPANCY :

n/a

FIRE ORIGIN LOCATION :

smoldering butt can 40' away from temporary circus tent

BUILDING CONSTRUCTION :

n/a

EXTENT WHEN DISCOVERED :

smoldering

EXTENT WHEN EXTINGUISHED :

extinguished

CAUSE OF FIRE :

cigarette butts

WHAT BURNED :

cigarette butts / trash in butt can

ESTIMATED PROPERTY LOSS :

none

DAMAGE TO :

n/a

COMMAND POST LOCATION :

n/a

STAGING AREA :

n/a

LIST AGENCIES NOTIFIED :

n/a

### RESPONDERS AT SCENE

FIRE OFFICERS: Carter

SAFETY PERSONNEL:

MEDICAL PERSONNEL:

BRIGADE MEMBERS:

OPERATIONS:

SECURITY:

OFFSITE FIRE:

OFFSITE AMBULANCE:

OTHER (SPECIFY):

### ICS POSITIONS

INCIDENT COMMANDER : All n/a below

SAFETY OFFICER :

SECURITY LIAISON :

OPERATIONS CHIEF :

LOGISTICS CHIEF :

PLANNING CHIEF :

STAGING OFFICER :  
MEDICAL LEADER :  
OTHER (Specify) :

**INCIDENT REPORTING**

REPORTING PARTY : plant employee by phone call to fire station  
CONTROL ROOM NOTIFIED

No  Yes  VIA: Phone  779  Other  Specify:

INDUSTRIAL FIRE OFFICER NOTIFIED :

No  Yes  VIA: Phone  Pager  PA  Other  Specify:

WITNESS(ES)

Name and Title :

**LIST FIRE PROTECTION OR DETECTION SYSTEM(S) ACTIVATED**

n/a

**LIST FIRE FIGHTING EQUIPMENT USED**

5 gallon water bottle

**NARRATIVE**

Received a phone call regarding a smokdering butt can in Area 10 by the temporary circus tent. The butt can is located approx 40 west of the east curtain door. Upon arrival, opened the top and poured approx 3 gallons of water inside from a 5 gallon water bottle. Replaced top and cleared scene.

---

---

NAME : Eric Carter                      DATE : 11/27/07      SIGNATURE: \_\_\_\_\_

REVIEWED BY : \_\_\_\_\_                      DATE : \_\_\_\_\_