

CHAPTER FOUR
TRANSMISSION FACILITIES

4.0 TRANSMISSION FACILITIES

This section describes the transmission facilities proposed to interconnect the proposed power plant with the Southern California Edison (SCE) substation located directly adjacent to the proposed plant.

4.1 INTERCONNECTION TO TRANSMISSION GRID

Generation from the San Gabriel Generating Station (SGGS) will be delivered to SCE's Rancho Vista substation by a single circuit 525-kilovolt (kV) transmission line from the site. A conceptual diagram showing the proposed interconnection is shown on Figure 4.1-1. This diagram shows the 525-kV circuit that runs directly from the dead-end structure to the SCE substation. The total length of the SGGS transmission line will be approximately 1,100 feet.

Reliant has filed an application for interconnection of the plant with the California Independent System Operator (CAISO).

4.2 INTERCONNECTION CONFIGURATION

4.2.1 Structures

The SGGS generation output system will use a variety of steel structures to support the disconnect switches, strain bus, and outgoing transmission line. The disconnect switches will be center-break, single-pole switches mounted horizontally on a two-leg support structure. The height of the live parts of the disconnect switches will be 35 feet above grade. There will also be three single-phase bus support structures (per transformer) at the same height that will support the conductor from the disconnect switch to the overhead strain bus tap.

The 525-kV strain bus will be supported by four approximately 65-foot-high A-frames, with 25 feet of phase-to-phase clearances, and one approximately 110-foot-high frame with 27-foot clearances, as shown in Figure 4.2-1, for a total of five of these structures. The transmission line will continue to the south from the western end of the strain bus, terminating on a 120-foot, 5-inch-high pole and interconnect to the SCE substation.

4.2.2 Conductors

The selection of conductor for the 525-kV line into the substation will be a bundle of two 2156 ACSR. This conductor is expected to carry the full current output of the power plant and is proposed for connecting the generator collector bus and SCE's switchyard.

The 525-kV deadend insulator assemblies will have polymer insulator strings. In addition, the assemblies will include hardware pieces including shackles, yoke plates, conductor termination clamps, and corona rings.

4.2.3 Foundations

Foundations for the strain bus structures will consist of single concrete piers reinforced as necessary to withstand design loads. These will be formed by auguring a hole of appropriate diameter and depth, placing a cage of reinforcing steel in the augured hole, and filling the hole with high-strength concrete to the appropriate elevation.

4.3 ELECTROMAGNETIC FIELD/RADIO-TELEVISION INTERFERENCE

The electrical transmission interconnection and other electrical devices that will be constructed as part of the proposed project emit electromagnetic fields (EMF) when in operation. These fields are typically measured near ground level where they are encountered by people. In addition, operation of electrical transmission lines can cause interference with radio and TV signal reception.

EMF fields, to the extent they occur, could impact receptors on the properties adjacent to the proposed project site. In addition, radio and TV interference could occur at nearby residences.

The plant site will be enclosed by a security fence. Site access will be limited to station workers, incidental construction and maintenance personnel, other company personnel, regulatory inspectors, and approved guests. Since access will not be available to the general public, general public exposure to EMF is not expected to occur from the SGGS facility.

The nearest TV or radio receptor is located approximately 0.4 mile northeast from the proposed project site. Radio and television interference would therefore be negligible due to the distance between the proposed site and nearest receptor. The transmission circuit line loading is presented in Table 4.3-1.

4.4 CONSTRUCTION

Construction of the interconnection line between the SCE Rancho Vista substation and the SGGS will be undertaken by SGPG. Construction will be scheduled for completion after the Rancho Vista substation, which is currently under construction, has been completed.

Construction of the interconnection will be on the SGGS site right-of-ways on land owned by IEUA and the Rancho Vista substation and will not disturb any offsite areas with public access.

4.5 SYSTEM IMPACT STUDY

The CAISO will conduct a System Impact Study to assess the downstream impacts of interconnecting the proposed project to the electric transmission system.

San Gabriel Power Generation, LLC (SGPG) does not expect any downstream impacts (beyond the Rancho Vista Substation) from the addition of the SGGS on the CAISO controlled grid. In 2005, the CAISO Board approved the addition of the Rancho Vista 500/230 kV Substation Project. A copy of the memorandum to the Board requesting its approval is included in Appendix I. As noted in the Executive Summary of that memorandum, the Rancho Vista Substation Project is needed to meet load growth in the area. This need is accelerated by the potential retirement of existing generation in the area. SCE is in the process of designing and constructing these significant transmission network upgrades in the vicinity of the SGGS, which are part of the 500/230 kV Rancho Vista Substation Project. Since the identified need for the Substation Project is to provide additional load serving capability in this area, the installation of additional generation at this substation fits directly with the need. A page from the 2006 CAISO Transmission Plan showing the approved status of the Rancho Vista Substation is also included in Appendix I. With the completion of the Substation Project in June 2009, the transmission system will be well situated for the new SGGS.


On January 23, 2007, SGPG and the CAISO entered into an agreement to initiate the System Impact Study. Copies of the agreement and proof of payment are provided in Appendix I.

SCE is planning to issue a draft System Impact Study (SIS) to the CAISO on May 25, 2007. The CAISO has thirty (30) days to comment on the draft SIS and return a final SIS to SCE. SCE and Reliant will then

enter into an agreement to conduct a Facility Study Agreement. SCE will then have ninety (90) days to produce a design for the interconnection of the SGGs with the Rancho Vista substation. The design is expected to be available by October 2007.

[Rest of page intentionally left blank.]

Table 4.3-1 Transmission Circuit Line Loading		
Transmission Lines on Same Tower	Phasing Sequence (Top to Bottom)	Line Amps
Reliant Etiwanda – SCE No. 1 500 kV	ABC (north to south)	3,244
Reliant Etiwanda – SCE A-Frame tower #38	ABC (west to east)	3,244
Reliant Etiwanda – SCE dead-end pole #39	BAC (top to bottom)	3,244



SGGS INTERCONNECTION TO THE SCE RANCHO VISTA SUBSTATION


San Gabriel Generating Station
 San Gabriel Power Generation, LLC
 Rancho Cucamonga, California

May 2007
 28067169



REPLACEMENT FIGURE 4.1-1

Source:
 Sargent & Lundy, General Arrangement Property Development Plan,
 Siemens 501F 2x2x1 Combined Cycle
 Drawing No. GA-06-2 (Rev. 3), 03-12-2007 (ga-06aa.dgn)




**AERIAL VIEW
WITH SGGS ELECTRICAL EQUIPMENT**

San Gabriel Generating Station
San Gabriel Power Generation, LLC
Rancho Cucamonga, California



May 2007
28067169

URS



NEW FIGURE 4.1-2



DEAD END POLE



65' A-FRAME



110' A-FRAME

Source:
Sargent & Lundy, T06_Transmission.dgn,
03-12-2007

TRANSMISSION LINE TOWERS

April 2007
28067169

San Gabriel Generating Station
San Gabriel Power Generation, LLC
Rancho Cucamonga, California



FIGURE 4.2-1