

Docket Optical System - 06-AFC-10 Fwd: 5/14/07 Site Elevation + 100 yr flood plain for Starwood Power

From: Che McFarlin
To: Docket Optical System
Date: 7/6/2007 8:47 AM
Subject: 06-AFC-10 Fwd: 5/14/07 Site Elevation + 100 yr flood plain for Starwood Power

I thought this email was previously docketed but as far as I can tell it doesn't appear on the docket log. If it's not already in the system please docket it. It does not need to be distributed.

Thanks for your help.

>>> <Amy_Gramlich@URSCorp.com> 5/14/2007 11:39 AM >>>

Che,

As requested, provided below, is a revised response to item 2:

DOCKET	
06-AFC-10	
DATE	MAY 14 2007
RECD.	JUL 06 2007

2) Source of fill material to raise the site elevation by 3ft. We've been informed that the soil would come from on site but how that would be accomplished has not been explained.

The source of fill material to raise the top of foundations by 3ft will be pulled from the on-site evaporation pond. Further, the site will be re-graded, as needed, to generate any additional required fill material (this includes material from within the vehicle turn-around "loop" area on-site). Top soil will be replaced at existing grade with compacted gravel. Concrete will be used to build up foundations to the required 3ft. The areas surrounding the foundations will be regraded to slope up to the foundations.

Please let us know if this is an adequate response or you have any further questions. Thank you!

Kindly,

Amy Gramlich,
 Environmental Specialist
 URS Corporation
 1615 Murray Canyon Road, Suite 1000
 San Diego, CA 92108
 www.urscorp.com
 Tel: 619.294.9400 ex:1151
 Fax:619.293.7920
 amy_gramlich@urscorp.com

This e-mail and any attachments are confidential. If you receive this message in error or are not the intended recipient, you should not retain, distribute, disclose or use any of this information and you should destroy the e-mail and any attachments or copies.

Angela Leiba/SanDiego/URSCorp

----- Forwarded by Angela Leiba/SanDiego/URSCorp on 05/07/2007 10:25 AM -----

"Che McFarlin"
 <Cmcfarli@energy.state.ca.us>

05/04/2007 05:02 PM

To"Angela Leiba"
 <Angela_Leiba@URSCorp.com>

CC

SubjectRe: Fw: Draft Starwood Power-Midway

Analysis

Hi Angela,

We're still waiting on a few minor pieces of information. See below. Given the delay in receiving some materials such as this PDOC, which we expect to receive in it's entirety on Monday, and the peak workload we're experiencing we do not expect to be able to deliver the PSA ahead of schedule.

1) The quantity of spent SCR catalyst expected to be disposed of every 3 to 5 years (per table 5.14.-3 of the AFC).

2) Source of fill material to raise the site elevation by 3ft. We've been informed that the soil would come from on site but how that would be accomplished has not been explained.

Have a good weekend.

Che McFarlin
Siting Project Manager
California Energy Commission
1516 Ninth Street
Sacramento, CA 95814

tel: 916.651.0965
fax: 916.654.3882