

CALIFORNIA ENERGY COMMISSION
REPORT OF CONVERSATION Page 1 of 1



**Systems Assessment and
 Facilities Siting Division**

FILE: 06-AFC 02

PROJECT TITLE: Highgrove Peaker - AES


<input checked="" type="checkbox"/> Telephone	(916)654-4170	<input type="checkbox"/> Meeting Location: Telephone Conversation
NAME:	Ellie Townsend-Hough	DATE: August 9, 2006
WITH:	Kristen Riegel	
SUBJECT:	: AES & CUPA Regulatory Relationship	

I spoke with Kristen Riegel, San Bernardino County, Fire Department , Haz Mat Division, Field Services at (909)386-8401.

Kristen mentioned she sent a letter to the Commission, June 23, 2006. The letter addressed concerns related to the Highgrove Project Section 8.12 (Hazardous Materials Handling) of the application.

Kristen talked to Julie Way at AES, August 7, 2006 about the San Bernardino County Certified Unified Program Agency (CUPA) performing an inspection of the Highgrove facility. The facility is in violation of their Business Plan, California Health and Safety Code, 25505. AES has received a Notice to Comply. The CUPA does not know how much hazardous materials and hazardous waste is on the project site. There may be some underground storage tank issues. There is an oily/water separator tank and a diesel tank on the site. The project has not been inspected in three years.

I attached hard copies of the letter, dated June 23 and the Notice to Comply.



I cc:	Bob Worl	Signed:
		Name: Ellie Townsend-Hough