

**CALIFORNIA ENERGY COMMISSION**1516 NINTH STREET  
SACRAMENTO, CA 95814-5512**DOCKET**  
**06-AFC-4**

DATE JUL 11 2006

RECD. JUL 11 2006

**NOTICE OF RECEIPT**  
**APPLICATION FOR CERTIFICATION**  
**VERNON POWER PLANT PROJECT**  
**Docket No. (06-AFC-4)**

On June 30, 2006, the City of Vernon submitted an Application for Certification (AFC) to construct and operate a combined-cycle power plant, the Vernon Power Plant Project (VPP), in the City of Vernon, Los Angeles County.

The VPP would be a 943 megawatt (MW) combined-cycle power plant consisting of three Siemens SGT6-5000F natural gas-fired combustion turbine generators equipped with Ultra Low Nitrogen (ULN) oxide combustors; three heat recovery steam generators (HRSG) with duct burners; one condensing steam turbine generator; a deaerating surface condenser; a 14-cell mechanical-draft cooling tower; and associated support equipment. The project will include an electric auxiliary boiler, but will not include a standby generator or black start capability. The project is expected to have an overall annual availability of 92 to 98 percent.

Associated equipment will include emission control systems necessary to meet the proposed emission limits. Nitrogen oxide (NO<sub>x</sub>) emissions will be controlled at the stack by a combination of ULN combustors in the CTGs and selective catalytic reduction systems in the HRSGs. An oxidation catalyst will be installed in the HRSGs to limit stack carbon monoxide (CO) emissions.

The proposed VPP site would be located at the southeast corner of Fruitland and Boyle Avenues. The City has executed a purchase agreement for the 27-acre parcel in an industrially zoned area in the City of Vernon. As part of the purchase agreement, the seller committed to: (1) obtaining permits and demolishing all structures on the site; (2) complying with all environmental laws regarding site cleanup; and (3) obtaining all necessary site closure certificates. In late 2006, the existing manufacturing facility will be demolished and the title transferred. The project site will consist of approximately 13.7 acres of the subdivided 27-acre parcel. The remaining 13.3 acres will be available during construction for parking and equipment laydown. Once construction is completed, the 13.3-acre property will be available for the City's future use.

For cooling tower make-up and other uses, the VPP will use up to 6,266 acre feet per year (afy) of recycled water provided by the Central Basin Municipal Water District (CBMWD). The recycled water will be delivered to VPP through a recycled water pipeline in Boyle Avenue, adjacent to the site. Cooling water would be cycled in the cooling tower five times.

Potable water for drinking, safety showers, fire protection, service water, and sanitary uses will be served from the City's potable water system.

Sanitary and cooling process wastewater will be delivered to the Sanitation Districts of Los Angeles County (LACSD) via the City's sanitary sewer system. A new sewer line connection will be added to connect to the County's system. Specifically, the VPP would include a new 18-inch sanitary sewer line exiting the plant site from the southeast corner, following along the east property line and an abandoned railroad right-of-way to Alcoa Avenue. Turning south on Alcoa Avenue, the line would then be 21 inches in diameter to the point where it

July 11, 2006

Page 2

will connect to the LACSD's 24-inch line at Alcoa and Slauson Avenues. The total distance of the new line would be 2,400 feet.

The VPP will connect to the electrical transmission system via a new double circuit 230-kilovolt (kV) line that will connect to Southern California Edison's (SCE) Laguna Bell Substation. The 230-kV transmission lines will run from the project site to the existing SCE Laguna Bell Substation via one of two route options. Both of these routes will be less than 5 miles in length and require crossing the Los Angeles River.

The transmission line in the Randolph Route Option would leave the VPP headed east for approximately 150 yards to an existing utility corridor. The line would then proceed south to Randolph Street turning east and then running approximately four miles to the Laguna Bell Substation. The new line would combine and replace two existing 66-kV lines.

The River Route exits the site to the east between 5151 and 5233 Alcoa Street, crosses Alcoa, and approaches the Los Angeles Department of Water and Power (LADWP) right-of-way through the parking lot at 5208 Alcoa. It continues by crossing the LADWP right-of-way and turning north on an easement on the east side of the LADWP right-of-way. The route turns north on this new easement along the LADWP right-of-way and proceeds to the south side of the SCE Leonis Substation. From there the route turns east between the south side of the Leonis Substation and the north side of the City of Vernon Fire Station to the west side of Downey Road. At Downey the route turns north to District Boulevard. The route crosses Downey Avenue to the northeastern corner of District Boulevard and continues east on the north side of District Boulevard, turning northeast (toward the Los Angeles River) between the properties at 4713 and 4717 District Boulevard. The route then crosses the Union Pacific railroad facilities and then the Los Angeles River. Along the eastern bank of the Los Angeles River the route turns south and follows the river to Randolph Street and the junction of the right-of-way currently occupied by two parallel 66-kV circuits (Laguna Bell-Leonis #2 and Laguna Bell-Ybarra). Both these circuits currently serve the City of Vernon. Finally, the route turns east along the north side of Randolph Street, crosses the I-710 Freeway, and proceeds to the Laguna Bell Substation. The new transmission line, along this section of Randolph Street, would replace the Laguna Bell-Container-Pulpgen-Vernon and the Laguna Bell-Leonis-Vernon circuits (66 kV) in the right-of-way currently occupied by them.

Natural gas will be delivered to the site via a new 24-inch-diameter pipeline. This 2,300-foot-long pipeline would exit the plant site heading east along East 50th Street, north on Alcoa Avenue and east on Fruitland Avenue to the Southern California Gas Company's (SoCalGas) transmission pipeline (Line 765) on Downey Road. At the plant site, the natural gas will pass through a flow-metering station, gas scrubber/filtering equipment, a gas pressure control station, electric-driven booster compressors (when required), and a fuel gas heater prior to entering the combustion turbines.

The City expects to receive a license from the Energy Commission by June 2007, with construction of the project starting in late summer 2007 assuming execution of a power purchase agreement with an energy retail provider and completion of project financing. Full-scale commercial operation would begin during the third quarter of 2008.

## **Energy Commission's Facility Certification Process**

The Energy Commission is responsible for reviewing and ultimately approving or denying all thermal electric power plants, 50 MW and greater, proposed for construction in California. The Energy Commission's facility certification process carefully examines public health and safety, environmental impacts and engineering aspects of proposed power plants, and all related facilities such as electric transmission lines, water, sewer, and natural gas pipelines. The Energy Commission's responsibilities are those of a lead agency under the California Environmental Quality Act (CEQA), except the Commission's analysis takes the form of several environmental and decision documents rather than an Environmental Impact Report.

The first step in the review process is for Energy Commission staff to determine whether or not the AFC contains all the information required by our regulations. When the AFC is deemed data adequate, we will begin data discovery and issue analysis phases. At that time, a detailed examination of the issues will occur.

## **Public Participation**

Over the coming months, the Energy Commission will conduct a number of public workshops and hearings to determine whether the project should be approved for construction and operation and under what set of conditions. These workshops will provide the public and local, State and federal agencies the opportunity to ask questions and provide input about the proposed project. The Energy Commission will issue notices for these workshops and hearings at least 10 days prior to the meeting.

If you desire information on participating in the Energy Commission's review of the project, please contact Ms. Margret Kim, the Energy Commission's Public Adviser, at (916) 654-4489 or toll free in California, at (800) 822-6228. The Public Adviser's Office can also be contacted via email at [pao@energy.state.ca.us](mailto:pao@energy.state.ca.us). Please direct your technical or schedule questions to James W. Reede, Jr., Energy Commission Project Manager, at (916) 653-1245, or [jreede@energy.state.ca.us](mailto:jreede@energy.state.ca.us). The status of the project, copies of notices, an electronic version of the AFC, and other relevant documents are also available on the Energy Commission's Internet web site at: [www.energy.ca.gov/sitingcases/cityofvernon](http://www.energy.ca.gov/sitingcases/cityofvernon). You can also receive email notification of all project related activities and availability of reports by subscribing to the Listserve on the website. News media inquiries should be directed to Assistant Executive Director, Claudia Chandler, at (916) 654-4989.

This notice of receipt has been mailed to all parties that requested placement on the mailing list during the pre-filing period and to property owners located within 1000 feet of the proposed project site and within 500 feet of any linear feature. By being on the mailing list, you will receive notices of all project-related activities and notices when documents related to the project's evaluation are available for review. If you wish to be removed from the mailing list, please contact Ms. Angela Hockaday, Project Secretary, at (916) 654-3925, or e-mail at [ahockada@energy.state.ca.us](mailto:ahockada@energy.state.ca.us).

July 11, 2006

Page 4

### Availability of the AFC Document

Copies of the AFC are available for public inspection at:

Bell Branch Library  
4411 E. Gage Avenue  
Bell, CA 90201

Huntington Park Library  
6518 Miles Avenue  
Huntington Park, CA 90255

Cudahy Branch Library  
5218 Santa Ana St.  
Cudahy, Ca 90201

City of Vernon Library  
4305 South Santa Fe Street  
Vernon, Ca 90058

Copies are also available at the Energy Commission's Library in Sacramento, the California State Library in Sacramento, and at public libraries in Los Angeles, San Francisco, San Diego, Fresno, and Eureka. In addition, copies will be distributed to those public agencies that would normally have jurisdiction except for the Energy Commission's exclusive authority to certify sites and related facilities.

DATE: 7/11/06



Roger E. Johnson, Manager  
Energy Facilities Siting and Compliance Office

Mailed to list