



San Joaquin Valley
AIR POLLUTION CONTROL DISTRICT

DOCKET	
06-AFC-5	
DATE	MAR 07 2007
RECD.	MAR 12 2007

March 7, 2007

Richard Perkins
County of Fresno
Planning & Resource Management
2220 Tulare Street, Suite A
Fresno, CA 93721

Project: Panoche Energy Center (06-AFC-5)

Subject: CEQA comments regarding the proposed 400-megawatt (MW) simple-cycle power plant to be located at 43649 Panoche Road, Firebaugh

District Reference No: 200700308

Dear Mr. Perkins:

The San Joaquin Valley Unified Air Pollution Control District (District) has reviewed the project referenced above and offers the following comments:

The California Energy Commission (CEC) has permitting authority over thermal energy facilities (power plants) that generate 50 MW or more of electricity. As such, the CEC is the Lead Agency for CEQA purposes. The District's duty as a Responsible Agency is to evaluate the project and ensure compliance with all applicable Federal, State, and District Rules and Regulations relating to air quality and to make a Determination of Compliance (DOC). The CEC will then incorporate all conditions of the DOC within the final certification of the power plant.

The San Joaquin Valley Air Basin is currently designated as serious non-attainment for Ozone and non-attainment (no classification) for PM2.5. On October 30, 2006, the US EPA found that the San Joaquin Valley had attained the PM10 standard. The US EPA based its determination upon monitoring data demonstrating that the ambient air quality had met the requirements for attainment. The US EPA's finding does not change the District's classification as a serious PM10 non-attainment to attainment area. However, re-designation from serious non-attainment to attainment requires additional documentation and will occur at some future date.

Seyed Sadredin
Executive Director/Air Pollution Control Officer

PROOF OF SERVICE (REVISED 12/19/06) FILED WITH ORIGINAL MAILED FROM SACRAMENTO ON 3/12/07

ARH

Northern Region
4800 Enterprise Way
Modesto, CA 95356-8718
Tel: (209) 557-6400 FAX: (209) 557-6475

Central Region (Main Office)
1990 E. Gettysburg Avenue
Fresno, CA 93726-0244
Tel: (559) 230-6000 FAX: (559) 230-6061
www.valleyair.org

Southern Region
2700 M Street, Suite 275
Bakersfield, CA 93301-2373
Tel: (661) 326-6900 FAX: (661) 326-6985

The District has reviewed Application for Certification (AFC) Section 5.02 – Air Quality and concludes the project would contribute to the overall decline in air quality due to emissions generated by the following activities:

Construction Emissions - The project's construction emissions will exceed the District's Thresholds of Significance for ozone precursors of 10 tons per year of reactive organic gases (ROG) and oxides of nitrogen (NOx). These emissions, however, are temporary in nature and should not have a long-term impact on air quality.

Operational (permitted source) Emissions – The project will generate emissions that exceed the District's Thresholds of Significance of 10 tons per year for ROG and NOx. As stated above, the CEC incorporates all conditions of the DOC in the final certification of the power plant. Therefore, the project will comply with all District rules and will reduce the operational emissions to a level of insignificance (less than 10 tons per year for ROG and NOx).

Area (mobile source) Emissions – The project's area emissions will not exceed the District's Thresholds of Significance of 10 tons per year for ROG and NOx.

District staff is available to meet with you and/or the applicant to further discuss the regulatory requirements that are associated with this project. If you have any questions or require further information, please call Jessica R. Willis at (559) 230-5818 and provide the reference number at the top of this letter.

Sincerely,

David Warner
Director of Permits Services


for Arnaud Marjollet
Permit Services Manager

DW:jrw

cc: James W. Reede, Jr., CEC
File

BEFORE THE ENERGY RESOURCES CONSERVATION AND DEVELOPMENT COMMISSION OF THE
STATE OF CALIFORNIA

APPLICATION FOR CERTIFICATION
FOR THE PANOCHÉ ENERGY
CENTER

Docket No. 06-AFC-5
PROOF OF SERVICE
(Revised 12/19/06)

INSTRUCTIONS: All parties shall 1) send an original signed document plus 12 copies OR 2) mail one original signed copy AND e-mail the document to the web address below, AND 3) all parties shall also send a printed OR electronic copy of the documents that shall include a proof of service declaration to each of the individuals on the proof of service:

CALIFORNIA ENERGY COMMISSION
Attn: Docket No. 06-AFC-5
1516 Ninth Street, MS-4
Sacramento, CA 95814-5512
docket@energy.state.ca.us

APPLICANT

Gary R. Chandler
Panoche Energy Center, LLC
P.O. Box 95592
South Jordan, UT 84095-0592

APPLICANT CONSULTANTS

Maggie Fitzgerald, Program Manager
URS
2020 East First Street, Suite 400
Santa Ana, CA 92705

COUNSEL FOR APPLICANT

Allan Thompson
21 "C" Orinda Way, No. 314
Orinda, CA 94563
allanori@comcast.net

INTERESTED AGENCIES

Larry Tobias
Ca. Independent System Operator
151 Blue Ravine Road
Folsom, CA 95630
LTobias@caiso.com

Electricity Oversight Board
770 L Street, Suite 1250
Sacramento, CA 95814
esaltmarsh@eob.ca.gov

INTERVENORS

CURE
Gloria D. Smith
Adams Broadwell Joseph & Cardozo
601 Gateway Boulevard, Suite 1000
South San Francisco, CA 94080
gsmith@adamsbroadwell.com

CURE
Marc D. Joseph
Adams Broadwell Joseph & Cardozo
601 Gateway Boulevard, Suite 1000
South San Francisco, CA 94080
mdjoseph@adamsbroadwell.com

Paul Kramer, Jr.
Hearing Officer
pkramer@energy.state.ca.us

James Reede
Project Manager
jreede@energy.state.ca.us

ENERGY COMMISSION

JEFFREY D. BYRON
Presiding Member
jbyron@energy.state.ca.us

Dick Ratliff
Staff Counsel
dratliff@energy.state.ca.us

JAMES D. BOYD
Associate Member
jboyd@energy.state.ca.us

Margret J. Kim
Public Adviser
pao@energy.state.ca.us

DECLARATION OF SERVICE

I, Angela Hockaday, declare that on March 12, 2007, I deposited copies of the attached CEQA Comments Regarding the Proposed 400-megawatt (MW) Simple-cycle Power Plant for the Panoche Energy Center project (06-AFC-5), in the United States mail at Sacramento, California with first-class postage thereon fully prepaid and addressed to those identified on the Proof of Service list above.

OR

Transmission via electronic mail was consistent with the requirements of California Code of Regulations, title 20, sections 1209, 1209.5, and 1210. All electronic copies were sent to all those identified on the Proof of Service list above.

I declare under penalty of perjury that the foregoing is true and correct.



[signature]