

**Docket Optical System - Transmission Engineering information for KRCDD
Community Power Project**

From: Che McFarlin
To: Docket Optical System
Date: 4/3/2008 6:22 PM
Subject: Transmission Engineering information for KRCDD Community Power Project
CC: Shaelyn Strattan

Please docket the following email which was received from PG&E on 3/26/08.

Leiping:

Per our conversation yesterday, this is to confirm that both CAISO and PG&E had agreed not to evaluate the Category "C" emergency overloads for the subject project in view of already large among normal and Category "B" emergency overloads that the study has revealed. The study has estimated more than \$ 120 million cost to mitigate these normal and Category "B" emergency overloads alone. There are event much more Category "C" emergency overloads to be evaluated, but it was not economically mitigating these overloads. Therefore the study report was not addressed Category "C" emergency overload at time it was issued.

By the way there is a typo on the report summary table on pg 1. Cat "C" should be Cat "B".

If you have any questions, please let us know.

Thanks.

Albert Wong
PG&E Transmission Planning

DOCKET	
07-AFC-7	
DATE	MAR 26 2008
RECD.	APR 04 2008